



ATTENTION

Post at Job Site

Touch 'n Seal® Gun Foam II polyurethane foam sealant has been approved by the International Code Council (ICC) as a fireblock penetration sealant. ICC evaluation report #ESR-1926 is available on request, or online at www.ICC-ES.org.

INSTALLATION SPECIFICATIONS

- Refer to manufacturer's instructions on product label for general use guidelines.
- Foam shall be installed to completely fill the annular space around the penetration(s) for the full depth of the plate that has been penetrated.
- Maximum width of exposed foam or the annular space of penetrations to be sealed must not exceed 1 5/16 inches (34mm).
- Nominal foam thickness shall not exceed 1½ inches (38 mm).
- Maximum area of exposed foam shall not exceed 15.5 square inches per square foot (1250 cm²/m²) of wall area.

CONDITIONS OF USE

- Sealant shall not be used in applications where it will be directly exposed to sunlight or weather.
- A thermal barrier is not required when installation complies with specifications noted above.
- Use shall be limited to Type V nonfire-resistance-rated construction under the IBC and IRC.

Used as specified, Touch 'n Seal Gun Foam II complies with, or is a suitable alternative to what is specified in the following codes:

- 2003 International Building Code® (IBC)
- 2003 International Residential Code® (IRC)
- 1999 BOCA® National Building Code (BNBC)
- 1999 Standard Building Code® (SBC)
- 1997 Uniform Building Code™ (UBC)

